



中国国家强制性产品认证证书

证书编号: 2019011002194535

发证日期: 2022年12月07日

有效期至: 2024年06月11日

**认证委托人名称
及注册地址** 威森电子(珠海)有限公司
珠海市金湾区三灶镇阳春路3号

**产品生产者名称
及注册地址** 威森电子(珠海)有限公司
珠海市金湾区三灶镇阳春路3号

**生产企业名称
及生产地址** 威森电子(珠海)有限公司
广东省珠海市金湾区三灶镇阳春路3号

**产品名称和系列、
规格、型号** LED 模块用交流电子控制装置(LED控制装置,内装式,恒流模式,安全特低电压,ta:50°C,tc:90°C,
不可调光,定温热保护:110°C)
见附件,220-240V~,50/60Hz

**产品标准和
技术要求** GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求,特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书为变更证书,证书首次颁发日期:2019年06月11日
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



签发:

谢肇煦



中国质量认证中心



中国国家强制性产品认证证书

证书编号：2019011002194535

第 1 页 共 1 页

本证书及附件应同时使用，信息查验说明见证书页

纸号：

型号	输出电压(Vdc)	输出电流(mA)	输出功率(W)
G5RT20W500LRP	30-42VDC Max.55VDC	500mA (恒流)	15-21W
G5RT30W600LRP	30-42VDC Max.55VDC	600mA (恒流)	18-25.2W
G5RT30W700LRP	30-42VDC Max.55VDC	700mA (恒流)	21-29.4W
G5RT30W800LRP	30-40VDC Max.55VDC	800mA (恒流)	24-32W

以上控制装置均为 220-240V ~ , 50/60Hz



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019011002194535

Valid from: Dec.07,2022

Valid until: Jun.11,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT WEISEN ELECTRONIC (ZHUHAI) CO.,LTD.
No.3, YangChun Road, Sanzao Town, Jinwan District, Zhuhai City , Guangdong Province, China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER WEISEN ELECTRONIC (ZHUHAI) CO.,LTD.
No.3, YangChun Road, Sanzao Town, Jinwan District, Zhuhai City , Guangdong Province, China

NAME AND LOCATION OF THE FACTORY WEISEN ELECTRONIC (ZHUHAI) CO.,LTD.
No.3, YangChun Road, Sanzao Town, Jinwan District, Zhuhai City , Guangdong Province, China

PRODUCT MODEL(S) A.C. Supplied Electronic Controlgear For LED Modules (Built-in, Constant Current Mode, SELV ,
ta:50°C , tc:90°C, Non-Dimmable, Temperature Declared Thermally Protected:110°C)
See Appendix, 220-240V ~ , 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jun.11,2019

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2019011002194535

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

型号	输出电压(Vdc)	输出电流(mA)	输出功率(W)
G5RT20W500LRP	30-42VDC Max.55VDC	500mA (恒流)	15-21W
G5RT30W600LRP	30-42VDC Max.55VDC	600mA (恒流)	18-25.2W
G5RT30W700LRP	30-42VDC Max.55VDC	700mA (恒流)	21-29.4W
G5RT30W800LRP	30-40VDC Max.55VDC	800mA (恒流)	24-32W

以上控制装置均为 220-240V ~ , 50/60Hz



CHINA QUALITY CERTIFICATION CENTRE