

Certificate Number: AZ 69024146

Page: 0001



CERTIFICATE OF APPROVAL

Authorised marking: TUV024146EA

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC Guide 65 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER:

HEP TECH Co., Ltd.
No. 20, Jingke 7th Rd.
Nantun Dist., Taichung 408
Taiwan, R.O.C.

DESCRIPTION OF EQUIPMENT

Declared class:

POWER SUPPLY OR CHARGER

Product:

Current controlled independent LED Driver

Trade Name / Manufacturer:

Trademark of HEP GROUP

Model Number:

1) G5S10W200LR-Z , 2) G5S10W250LR-Z , 3) G5S10W350LR-Z
4) G5S10W450LR-Z , 5) G5S10W500LR-Z

Ratings:

220-240Vac; 50-60Hz; IP20: Class II; SELV;
Further Ratings details refer to CONTINUATION SHEET 1

Standard:

AS 61347.2.13:2018
AS/NZS 61347.1:2016+A1

Issue Date:

29/05/2020

Expiry Date:

29/05/2025

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Billy Chu', written over a horizontal line.

Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69024146

Page: 0002



CERTIFICATE OF APPROVAL

Authorised marking: TUV024146EA

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Ratings:

Input:

- 1): AC 220-240V, 50-60Hz, 56mA, PF=0.9C
- 2): AC 220-240V, 50-60Hz, 63mA, PF=0.9C
- 3): AC 220-240V, 50-60Hz, 66mA, PF=0.9C
- 4): AC 220-240V, 50-60Hz, 58mA, PF=0.9C
- 5): AC 220-240V, 50-60Hz, 63mA, PF=0.9C

Output:

- 1): DC 29-42V, 200mA, 5.8-8.4W, Uout=55V, tc=85°C
- 2): DC 26-40V, 250mA, 6.5-10W, Uout=53V, tc=85°C
- 3): DC 17-29V, 350mA, 6-10.1W, Uout=40V, tc=85°C
- 4): DC 13-20V, 450mA, 5.9-9W, Uout=29V, tc=85°C
- 5): DC 13-20V, 500mA, 6.5-10W, Uout=29V, tc=85°C

Operation ambient for all models: ta= -20 to 45°C

Issue Date: 29/05/2020

Expiry Date: 29/05/2025

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in black ink, appearing to read 'Billy Chu'.

Billy Chu



Acc. No. Z2870404AA
www.jas-anz.org/register